

# **Fire Safety Requirements:**

## **VEHICLE INSPECTION SITE**

There will be a check site located outside the freight doors during move-in where all boats, SUV's, RV's, and any other motorized vehicles must be inspected for fuel levels. This procedure is required in order to ensure public safety and meet Fire Marshall regulations. Upon inspection, you will be given a "pass" to enter the facility.

## **FUEL TANKS (3 Gallons or less)**

When vehicles or boats with fuel tanks are part of the display, fuel-tank caps must be equipped with a locking gas cap or taped closed and batteries disconnected. Fuel tanks should be empty. For vehicles that must be driven onto the show floor, Fire Marshal standards are the lesser of 3 gallons or less than a ¼ tank of fuel (sufficient to drive in/ out). Portable auxiliary fuel tanks are prohibited and must be removed.

## **FUEL CAP MUST BE TAPED**

All caps on fuel tanks must be taped down to discourage removing cap in the building.

## **DISCONNECT ALL BATTERIES**

The GND Terminal must be disconnected on all vehicles or power products.

## **USED PROPANE TANKS ARE PROHIBITED**

Any propane tanks in the building must have the original factory seal or they must be removed.

## **FIRE SAFETY REQUIREMENTS**

Everyone must comply with applicable rules, regulations and policies, including (without limitation) all fire rules, regulations, and policies.

## **FLAME-RETARDANT TREATMENT**

All decorations, drapes, signs, banners, cloth and decorative materials shall be rendered flame-retardant and labeled that treatment has been made. Combustible wood materials one-quarter inch or more in thickness may be used without flame-retardant treatment.

## **EXITS AND AISLES**

Aisles shall be kept clear of all display and equipment. Entrance and exit doors shall remain unobstructed at all times. Fire extinguishers and fire-hose cabinets shall remain visible and accessible at all times.

## **COMBUSTIBLES**

Literature on display shall be limited to reasonable quantities. Reserve suppliers shall be kept in closed containers and stored in a neat and compact manner. Exhibit storage cartons and crates, combustible waste materials, empty cardboard boxes, etc... must be removed from the building and can not be stored behind the back drapes or display wall. Show Management shall assume responsibility for adequate janitorial and rubbish pickup service outside your booth performed daily.

## **ELECTRICAL DEVICES**

All electrical devices with three-wire supply cords shall utilize "UL" ground receptacles. All electrical extension cords must be of heavy-duty three-wire construction. Fire Marshals reserve the right to **CLOSE THE SHOW** if proper extension cords are not used. Do not use two-wire extension cords.

## **NOTIFICATION & SPECIAL PERMITS**

As an exhibitor, you must obtain prior written approval from ISE and apply for a special permit (submitted at least 15 days in advance of the show) if you intend to display, operate, or use any of the below items:

- Heater, barbecue, heat producing or open-flame device, candles, lamps, lanterns, etc...
- Electrical, mechanical or chemical device deemed hazardous by the Fire Department.
- Internal-combustion engines.
- Flammable liquids compressed gasses or dangerous chemicals.

## **PROPANE AND HELIUM ARE PROHIBITED**